Missouri Department of Natural Resources



PUBLIC NOTICE

DRAFT MISSOURI STATE OPERATING PERMIT

DATE: September 22, 2006

In accordance with the state Clean Water Law, Chapter 644, RSMo, Clean Water Commission regulation 10 CSR 20-6.010, and the federal Clean Water Act, the applicants listed herein have applied for authorization to either discharge to waters of the state or to operate a no-discharge wastewater treatment facility. The proposed permits for these operations are consistent with applicable water quality standards, effluent standards and/or treatment requirements or suitable timetables to meet these requirements (see 10 CSR 20-7.015 and 7.031). All permits will be issued for a period of five years, unless noted otherwise in the Public Notice for that discharge.

On the basis of preliminary staff review and the application of applicable standards and regulations, the Missouri Department of Natural Resources (MDNR), as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions. The proposed determinations are tentative pending public comment.

Persons wishing to comment on the proposed permit conditions are invited to submit them in writing to the Department of Natural Resources, Southeast Regional Office, 2155 N. Westwood Blvd., Poplar Bluff, Missouri, 63901, ATTN: Gary L. Gaines, P.E., Regional Director. Please include the permit number in all comment letters.

Comments should be confined to the issues relating to the proposed action and permit(s) and the effect on water quality. The MDNR may not consider as relevant comments or objections to a permit based on issues outside the authority of the Clean Water Commission, (see <u>Curdt v. Mo. Clean Water Commission</u>, 586 S.W.2d 58 Mo. App. 1979).

All comments must be postmarked by October 22, 2006 or received in our office by 5:00 p.m. on October 25, 2006. The requirement of a signed document makes it impossible to accept email comments for consideration at this time. Comments will be considered in the formulation of all final determinations regarding the applications. If response to this notice indicates significant public interest, a public meeting or hearing may be held after due notice for the purpose of receiving public comment on the proposed permit or determination. Public hearings and/or issuance of the permit will be conducted or processed according to 10 CSR 20-6.020.

Copies of all draft permits and other information including copies of applicable regulations are available for inspection and copying at DNR's website, http://www.dnr.mo.gov/env/wpp/wpcp-pn.htm or at the Department of Natural Resources, Southeast Regional Office, 2155 N. Westwood Blvd., Poplar Bluff, Missouri, 63901, between the hours of 8:00 a.m. and 5:00 p.m., Monday through Friday.

Public Notice Date: September 22, 2006 Permit Number: MO-0115118

Southeast Regional Office

	-
FACILITY NAME AND ADDRESS	NAME AND ADDRESS OF OWNER
Name: Village of Kelso WWTF	Name: Village of Kelso
Address: Kelso, MO 63758	Address: P.O. Box 279
	Kelso, MO 63758
RECEIVING STREAM & LEGAL DESCRIPTION	TYPE OF DISCHARGE
Unnamed Trib to Ramsey Creek (U)	Domestic, Renewal
NE $\frac{1}{4}$, NE $\frac{1}{4}$, Sec 18, T29N, R14E	
Scott, County	

STATE OF MISSOURI

DEPARTMENT OF NATURAL RESOURCES



MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92nd congress) as amended,

Permit No.: MO-0115118

Owner: Village of Kelso

Owner's Address: PO Box 279, Kelso, MO 63758

Continuing Authority: Same as above Continuing Authority's Address: Same as above

Facility Name: Village of Kelso Wastewater Treatment Facility

Facility Address: Kelso, MO 63758

Legal Description: NE ¼, NE ¼, Sec. 18, T29N, R14E Scott County

Latitude/Longitude: +3710580/-08932427

Receiving Stream: Unnamed Tributary to Ramsey Creek (U)

First Classified Stream and ID: Ramsey Creek (P) (02346)

USGS Basin & Sub-watershed No.: (07140107-060003)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

FACILITY DESCRIPTION

Outfall #001 - 92-500/POTW - SIC #4952

Two cell aerated lagoon/Sludge is retained in lagoon.

Design population equivalent is 756.

Design flow is 75,600 gallons per day.

Actual flow is 51,000 gallons per day.

Design sludge production is 15 dry tons/year.

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

Effective Date	Doyle Childers, Director, Department of Natural Resources Executive Secretary, Clean Water Commission
Expiration Date MO 780-0041 (10-93)	Gary L. Gaines, P.E., Director, Southeast Regional Office

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

PAGE NUMBER 2 of 5
PERMIT NUMBER MO-0115118

The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The interim effluent limitations shall become effective upon issuance and remain in effect until the day prior to expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:

OUTEAU ANIMOED AND EEFLUENT	INTERIM EFFLUENT LIMITATIONS				MONITORING REQUIREMENTS	
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	DAILY \(\) MAXIMIUM	WEEKLY AWERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
TANAMETER(O)	UNITS	IVIASAVIOIVI	/ AVENAUE	AVERAGE	FREQUENCT	ITPE
0		111				
Outfall #001						
Flow	MGD ()) * \		*	Once/month	24 hr.
		$\langle \langle \rangle \rangle$				estimate
Biochemical Oxygen Demands**	mg/L		65	45	Once/month	grab
Total Suspended Solids **	mg/L		110	70	Once/month	grab
_ \		***		***		_
pH - Units	SIZ	***		***	Once/month	grab
Ammonia as N	mg/L	*		*	Once/month	grab
Temperature	°C	*		*	Once/month	grab
Oil & Grease	mg/L	15		10	Once/month	grab

MONITORING REPORTS SHALL BE SUBMITTED <u>Monthly;</u> THE FIRST REPORT IS DUE _______ DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.

THERE SHALL BE NO

The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective one day prior to expiration and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:

		FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Outfall #001						
Flow	MGD	*		*	Once/month	24 hr. estimate
Biochemical Oxygen Demands**	mg/L		65	45	Once/month	grab
Total Suspended Solids **	mg/L		110	70	Once/month	grab
pH - Units	SU	***		***	Once/month	grab
Fecal Coliform	#/100 mL	1000		400	Once/month	grab
Total Residual Chlorine (Note 1) ****	mg/L	.019 (.13ML)		.010 (.13ML)	Once/month	grab
Ammonia as N	mg/L	*		*	Once/month	grab
Temperature	°C	*		*	Once/month	grab
Oil & Grease	mg/L	15		10	Once/month	grab

MONITORING REPORTS SHALL BE SUBMITTED Monthly; THE FIRST REPORT IS DUE DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.

THERE SHALL BE NO

B. STANDARD CONDITIONS

IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Parts I, II & III</u> STANDARD CONDITIONS DATED <u>October 1, 1980 and August 15, 1994</u>, AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

* Monitor and report.

** This facility is required to meet a removal efficiency of 65% or more. Influent and effluent samples used to determine percent removal shall be taken the same day.

*** pH is measured in pH units and is not to be averaged. The pH is to be maintained at or above 6.0 pH units.

**** Final limitations and monitoring requirements for Fecal Coliforn are applicable only during the recreational season from April 1 through October 31.

Note 1 - This permit contains a Total Residual Chloring (TRC) limit

- (a) This effluent limit is below the minimum quantification level (ML) of the most common and practical EPA approved CLTRC methods. The department has determined the current acceptable ML for total residual chlorine to be 0.13 mg/L when using the DPD Colorimetric Method #4500. CL G. from Standard Methods for the Examination of Waters and Wastewater. The permittee will conduct analyses in accordance with this method, or equivalent, and report actual analytical values. Measured values greater than or equal to the minimum quantification level of 0.13 mg/L will be considered violations of the permit and values less than the minimum quantification level of 0.13 mg/L will be considered to be in compliance with the permit limitation. The minimum quantification level does not authorize the discharge of chlorine in excess of the effluent limits stated in the permit.
- (b) Disinfection is required year-round unless the permit specifically states that "Final limitations and monitoring requirements for Fecal Coliform are applicable only during the recreational season from April 1 through October 31." If your permit does not require disinfection during the non-recreational months, <u>do not chlorinate in those months</u>.
- (c) Do not chemically dechlorinate if it is not needed to meet the limits in your permit.
- (d) If no chlorine was used in a given sampling period, an actual analysis is not necessary. Simply report as "0 mg/L" TRC.

C. SPECIAL CONDITIONS

- 1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
 - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
 - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) controls any pollutant not limited in the permit.
 - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
 - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list. The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.
- 2. All outfalls must be clearly marked in the field.
- 3. Permittee will cease discharge by connection to areawide wastewater treatment system within 90 days of notice of its availability.

C. SPECIAL CONDITIONS (continued)

4. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
 - (1) One hundred micrograms per liter (100 µg/L)
 - Two hundred micrograms per liter (200 μ g/L) for acrolein and acrylonittile; five hundred micrograms per liter (500 μ g/L) for 2,5 dinitrophenol and for 2 methyl 4, o dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
 - (4) The level established in Part A of the permit by the Director.
- (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.
- 5. Report as no-discharge when a discharge does not occur during the report period.
- 6. General Criteria. The following water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
 - (a) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
 - (b) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
 - (c) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
 - (d) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life:
 - (e) There shall be no significant human health hazard from incidental contact with the water;
 - (f) There shall be no acute toxicity to livestock or wildlife watering;
 - (g) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
 - (h) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.
- 7. Sludge and Biosolids Use For Domestic Wastewater Treatment Facilities
 - (a) Permittee shall comply with the pollutant limitations, monitoring, reporting, and other requirements in accordance with the attached permit Standard Conditions.
 - (b) If sludge is not removed by a contract hauler, permittee is authorized to land apply biosolids. Permit Standard Conditions, Part III shall apply to the land application of biosolids. Permittee shall notify the department at least 180 days prior to the planned removal of biosolids. The department may require submittal of a biosolids management plan for department review and approval as determined appropriate on a case-by-case basis.

D. SCHEDULE OF COMPLIANCE

The final daily maximum and monthly average Fecal Coliform limits of 400/100ml and 1000/100ml, respectively, shall become effective one day prior to the expiration date of the permit or December 31, 2013, whichever comes first unless items 2 or 3 below are approved by the Department. The Effluent Regulation, 10 CSR 20 – 1015(9)(H), allows the permittee up to five years from the issuance date of this permit to:

- 1) Install disinfection facilities, or;
- 2) Present an evaluation to show that disinfection is not required to protect one or both recreational uses, or;
- Present a Use Attainability Analysis UAA) that demonstrates one or both designated recreational uses are not attainable in the classified waters receiving the effluent. For more information on UAA's please contact the Water Protection Program at (573) 751-1300.
- 4) Suggested timeline to comply with standard:
 - Submit evaluation or UAA if applicable within one year from issuance of this permit
 - b) If evaluation or UAA not applicable or submittal resulted in Whole Body Contact retention then submit a preliminary engineering report, prepared by a licensed professional engineer in the State of Missouri within two years from issuance of this permit. The preliminary engineeering report shall make recommendations to upgrade the wastewater treatment facility to include effluent disinfection equipment. (If a facility utilizes disinfection by chlorine, it may be required to dechlorinate the effluent.)
 - c) Submit construction permit application within three years from issuance of this permit and after approval of the preliminary engineering report by the Department. The application shall include applicable fees, plans and specifications in accordance with the approved preliminary engineering report.
 - d) Submit letter of authorization or statement of work complete signed by the owner and a licensed professional engineer in the State of Missouri prior to expiration of this permit.



				view Sheet Check List ing Permit Renewa			
Facility Information Facility Nan Facility Typ	ne: Vi	illage of Kelso Cell Aerated La	goon (92-500 Facility)		Remit #: Age:	MO-011 10 Year	
Outfall Char	racteristics						
Outfall	Design I	Flow (MGD)	Actual Flow (MGD)	Actual Flow/De	sign Flow		
001	.0756		051	68%			
Note: Estima	ited Flow I	Based On Dischar	ge Monitoring Report				
Effluent Cha	racteristic	es					
Biochemical (Total Suspend	Oxygen De	emand (BOD5)	In Compliance ⊠ In Compliance ⊠ In Compliance ⊠	Significant N	oncompliance oncompliance oncompliance]]] N/A	
Effluent Limi	t/Monitori	ng Requirement I	Frequency at regulatory r	minimum: Yes	⊠ No □		
Receiving W	aterbody 1	<u>Information</u>					
Waterbody I			butary to Ramsey Cree	k		Class:	<u>U</u>
Waterbody I	Name:	Ramsey Creel	k		•	Class:	P
Discharge to Use Attainabi	or within to ility Analys	wo (2) miles of a sis Conducted			ody contact recr		
			terbody types below, is v lucted, this form is not ap		encing rapid dev	velopment,	or if a site-specific
Lake/Reserv Outstanding		303(d) Waterb State Resource	oody Metropolii Water and Drainages	tan No-Discharge Γhereto	Stream		